

LAB FEDERAL ID#: <b>ID00952</b>		DATE REPORTED BY LAB <b>12/09/2024</b>	
DATE RECEIVED: <b>11/25/2024</b>			
COMPLIANCE SAMPL		REPLACEMENT SAMPL	
PWS #:	PWS NAME: <b>Aberdeen School District #58</b>		
CONTACT NAME: <b>Jane Ward</b>		CONTACT PHONE: <b>(208) 397-4113</b>	

# IAS EnviroChem

3314 Pole Line Rd.  
Pocatello, ID 83201  
phone: (208) 237-3300  
fax: (208) 237-3336  
email: iasec3308@iasenvirochem.com  
www.iasenvirochem.com

DEQ USE ONLY:	
90%ile Lead	
90%ile Copper	
# Pb/Cu Samples Reported	
Paperwork Attached?	Yes No

## Lead and Copper Analysis Report

FRDS	Lab Sample #	Sample Location	Collection Date	Analyte	Result	Units	MCL	MDL	Method	Analyzed	Analyst
1030	I411229-01	Aberdeen Old H.S.	11/25/24 05:30	Lead	0.003	mg/L	0.015	0.001	200.8	11/27/2024	TRP
1030	I411229-02	Aberdeen Elem School	11/25/24 05:36	Lead	0.002	mg/L	0.015	0.001	200.8	11/27/2024	TRP

ND = Not Detected      MCL = Maximum Contaminant Level      MDL = Method Detection Limit

Aberdeen School District #58  
Jane Ward  
P.O. Box 610  
Aberdeen, ID 83210



G. Ryan Pattie  
Laboratory Director